

Manganese Health Advisory = 0.3 mg/L

Water Systems under a Manganese Health Advisory

Concordia

LA1029002	Town Of Clayton Water System	State Issued Date:	4/2/2024
		Manganese Level:	0.96 mg/L

Iberia

LA1045040	Mjs Estates Water System	State Issued Date:	3/19/2024
		Manganese Level:	0.39 mg/L
LA1045042	Badger Trail Water System	State Issued Date:	2/26/2024
		Manganese Level:	0.74 mg/L

Lafayette

LA1055169	Windy Meadows Water System	State Issued Date:	2/26/2024
		Manganese Level:	0.58 mg/L

Morehouse

LA1067009	Mer Rouge Water System	State Issued Date:	2/26/2024
		Manganese Level:	0.93 mg/L

Richland

LA1083017	Palmetto Addiction Recovery	State Issued Date:	2/26/2024
		Manganese Level:	1.32 mg/L

St Landry

LA1097031	Cane View Mobile Home Village	State Issued Date:	2/26/2024
		Manganese Level:	0.79 mg/L

St Martin

LA1099025	My Place Mobile Home Park Water System	State Issued Date:	2/26/2024
		Manganese Level:	0.62 mg/L